	Fire Ala	arm Symbol l	egend				
SYMBOL	DESCRIPTION	PART NUMBER	MODEL	QUANTITY	USER TEXT	UL	FM
NAC	6 AMP EXPANDABLE NAC, 4 CIRCUIT	HPF24S6	HPF24S6	1		S6677	
◯ _{15CD}	STROBE, M-C, RED, CEILING	GCS24CR	GCS24CR	16		464, 1971	Approved
◯ 30CD	STROBE, M-C, RED, CEILING	GCS24CR	GCS24CR	2		464, 1971	Approved
◯ _{15CD}	STROBE, M-C, RED, CEILING	GCS24CR	GCS24CR	2	EX	464, 1971	Approved
∭ _{15CD}	HORN/STROBE, 2 WIRE, M-C, RED, CEILING	GCC24-CR	GCC24CR	8		464, 1971	Approved
∰ _{75CD}	HORN/STROBE, 2 WIRE, M-C, RED, CEILING	GCC24-CR	GCC24CR	2		464, 1971	Approved
∭ _{95CD}	HORN/STROBE, 2 WIRE, M-C, RED, CEILING	GCC24-CR	GCC24CR	7		464, 1971	Approved
\$	SMOKE, PHOTO, 2-WIRE	2W-B	2W-B	2	EX	S911	3011446
13 EOL 4.7K Ω	END OF LINE RESISTOR	EOL	EOL	4			
\$	SMOKE, PHOTO, 2-WIRE	2W-B	2W-B	1		S911	3011446
135°	135 °F (57° C) FIXED TEMP	5603	5603	2	EX	S2101	Approved
Н	HORN, RED	LHNR	LHNR	9	EX	UL 1971, UL464	
H⋈	HORN, RED	LHNR	LHNR	1	EX	UL 1971, UL464	

		Battery Calculations	for Panel: P1			
Part No:HPF24	S6 -	6 AMP EXPANDABLE NAC, 4 CIRCUIT				
Job number: 8-	17-0	206 Job name: TABLEAU				
Address 1: 401	PAR	K PLACE CENTER				
Address 2: KIRI	KLAN	ND, WA 98033				
Phone: (253)83	3-12	48 Fax: (253)735-0113				
Designing engir	neer:	MATT CARLMAN				
Job Site: KIRKL	AND	PARKPLACE				
Authority having	g juri	sdiction: CITY OF KIRKLAND				
Part No.	Qty.	Description	Standby	Total Standby	Alarm	Total Alarm
		Panel Equipment				
HPF24S6_MB	1	PANEL CARD, MAIN BOARD, 6A	91.0000mA	91.0000mA	145.0000mA	145.0000mA
			Total Panel Stby	91.0000mA	Total Panel Alarm	145.0000mA
		Peripheral Devices				
GCS24CR	20	STROBE, M-C, RED, CEILING (Notification)	0.0000mA	0.0000mA	120.0000mA	2400.0000mA
GCC24-CR	8	HORN/STROBE, 2 WIRE, M-C, RED, CEILING (Notification)	0.0000mA	0.0000mA	143.0000mA	1144.0000mA

GCC24-CR	6	HORN/STROBE, 2 WIRE, M-C, RED, CEILING (Notification)	0.0000mA	0.0000mA	243.0000mA	1458.0000mA
EOL	4	END OF LINE RESISTOR (Notification)	0.0000mA	0.0000mA	0.0000mA	0.0000mA
GCC24-CR	2	HORN/STROBE, 2 WIRE, M-C, RED, CEILING (Notification)	0.0000mA	0.0000mA	223.0000mA	446.0000mA
			Total Peripheral Stby	0.0000mA	Total Periph Alarm	5448.0000mA
			Total Standby Amps	91.0000mA	Total Alarm Amps	5593.0000mA
				St	andby time: 24 Hrs	2.184Ah
					Alarm time: 5 Min	0.466Ah
					Battery requirement:	2.65Ah
		Compensation Factors - S	Standby: 1.2 Alarm: 1.2	Requirement	with compensation:	3 18Ah


		Circuit Calculations Panel: P1 C	ard: 00	Circuit:SIG	3					
		CircuitName: SIG3								
		Circuit Type: Notification Terminal Voltage: 20.4	V:DC Am	perage: 2.0000A						
	Cable: 14/2 SOL JKT FPLP 1M RL RED #14									
		Calculations based on Running Tot	al Length.							
		Design Criteria: Ambient temperature: 167°F Max. o	perating vol	age drop: 10%						
Device	Part No	Appliance Desc	Distance	Current	Voltage	Voltage Drop				
	HPF24S6	Panel			20.4V					
1	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	23'-0	120.0000mA	20.2258V	(0.1742V)				
2	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 95CD	32'-0	243.0000mA	20.0026V	(0.2232V)				
3	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 95CD	62'-0	243.0000mA	19.6455V	(0.3571V)				
4	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	22'-0	120.0000mA	19.5455V	(0.1V)				
5	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	29'-0	120.0000mA	19.4311V	(0.1144V)				
6	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 15CD	18'-0	143.0000mA	19.3709V	(0.0602V)				
7	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	13'-0	120.0000mA	19.3367V	(0.0342V)				
8	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 15CD	11'-0	143.0000mA	19.3143V	(0.0223V)				
9	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	16'-0	120.0000mA	19.2933V	(0.021V)				
10	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 15CD	16'-0	143.0000mA	19.2819V	(0.0114V)				
10	EOL	END OF LINE RESISTOR	4'-0	0.0000mA	19.2819V	(0V)				
			246'-0	1515.0000mA						
				Т	otal Currer	nt: 1515.0000mA				
		(Tot	al VDrop Per	rcent:5.48%) To	otal Voltage	e Drop : 1.1181V				

									Ţ		ALA	RM		_	TF	OUBLE	SUPERVIS	SORY	MISCELLA	NEOUS	
									/	/ /											
CAUSE	thirt.		ATTACON AND AND AND AND AND AND AND AND AND AN	AMMIN	CHAN	R REPORT	A LING A STREET	2017		100 P	SOF	NO STATE OF THE ST	A STATE OF THE STA	NO THE STATE OF TH		A LEGAL			REMARKS		
	~~ <u>~</u>	7 7	~~	$\langle - \rangle$	7	//	-	~	77	\prec	37	9 ⁷ 9		7	97 4	/			T LIID U U U		
SMOKE / HEAT DETECTORS MANUAL PULL STATION		***	_	•	_	+	+		\vdash	+	+	\vdash	+	+	+						
SYSTEM RESET		45	•	•	-	_	+		\vdash	+	+	\vdash	\rightarrow	+	•						
SIGNAL SILENCE	-+	+		\vdash	\vdash	+	+		\vdash	+	+	\vdash	٠,	•							
AC POWER FAILURE	-	+	_	\vdash	\vdash	-	-	•		\rightarrow	+	\vdash		4	-						
	\rightarrow	+	_	\vdash	\vdash	-	-	•	-	+	+		-	+	+						
FIRE ALARM TROUBLE (OPEN, SHORTS, OR GROUNDS) ON								•													
INITIATION OR SIGNALING CIRCUITS							■	•	-												
TAMPER SWITCHES	-	+	_		\vdash	_	_		\vdash	-	•		_	+	+						
WATERFLOW SWITCH	-	•	•	•		_			\vdash		+•	-	\rightarrow	+	+						

		Circuit Calculations Panel: P1 (Card: 00	Circuit:SIG	3 4	
		CircuitName: SIG4				
		Circuit Type: Notification Terminal Voltage: 20.4	V:DC Am	perage: 2.0000A		
		Cable: 14/2 SOL JKT FPLP 1M RL	RED #14			
		Calculations based on Running To	tal Length.			
		Design Criteria: Ambient temperature: 167°F Max.	operating vol	tage drop: 10%		
Device	Part No	Appliance Desc	Distance	Current	Voltage	Voltage Drop
	HPF24S6	Panel			20.4V	
1	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	30'-0	120.0000mA	20.2007V	(0.1993V
2	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 75CD	20'-0	223.0000mA	20.0798V	(0.1209V
3	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	29'-0	120.0000mA	19.9368V	(0.143V
4	GCS24CR	STROBE, M-C, RED, CEILING, 30CD	28'-0	120.0000mA	19.8155V	(0.1212V
5	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 15CD	17'-0	143.0000mA	19.7521V	(0.0634V
6	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	13'-0	120.0000mA	19.7129V	(0.0392\
7	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	13'-0	120.0000mA	19.6815V	(0.0314V
8	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	24'-0	120.0000mA	19.638V	(0.0436V
9	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 95CD	33'-0	243.0000mA	19.5979V	(0.0401V
9	EOL	END OF LINE RESISTOR	3'-0	0.0000mA	19.5979V	(0V
			210'-0	1329.0000mA		
				Т	otal Currer	nt: 1329.0000m <i>A</i>
		(To	tal VDrop Per	rcent:3.93%) To	otal Voltage	e Drop : 0.8021V

		Circuit Calculations Panel: P1 C	ard: 00	Circuit:SIC	3 5				
		CircuitName: SIG5							
		Circuit Type: Notification Terminal Voltage: 20.4	V:DC Amp	erage: 2.0000/	Д				
	Cable: 14/2 SOL JKT FPLP 1M RL RED #14								
		Calculations based on Running To	al Length.						
		Design Criteria: Ambient temperature: 167°F Max. o	perating volt	age drop: 10%	1				
Device	Part No	Appliance Desc	Distance	Current	Voltage	Voltage Drop			
	HPF24S6	Panel			20.4V				
1	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 75CD	58'-0	223.0000mA	20.1132V	(0.2868V)			
2	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	22'-0	120.0000mA	20.0289V	(0.0843V)			
3	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 15CD	15'-0	143.0000mA	19.9805V	(0.0485V)			
4	GCS24CR	STROBE, M-C, RED, CEILING, 30CD	25'-0	120.0000mA	19.9176V	(0.0629V)			
5	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 15CD	12'-0	143.0000mA	19.8946V	(0.023V)			
6	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	15'-0	120.0000mA	19.8766V	(0.018V)			
7	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	13'-0	120.0000mA	19.8688V	(0.0078V)			
7	EOL	END OF LINE RESISTOR	3'-0	0.0000mA	19.8688V	(0V)			
			163'-0	989.0000mA					
					Total Curre	ent: 989.0000mA			
	(Total VDrop Percent:2.60%) Total Voltage Drop : 0.5312V								

		Circuit Calculations Panel: P1 C	ard: 00	Circuit:SIG	6	
		CircuitName: SIG6				
		Circuit Type: Notification Terminal Voltage: 20.4	V:DC Am	perage: 2.0000A		
		Cable: 14/2 SOL JKT FPLP 1M RL	RED #14			
		Calculations based on Running Tot	tal Length.			
		Design Criteria: Ambient temperature: 167°F Max. o	perating vol	tage drop: 10%		
Device	Part No	Appliance Desc	Distance	Current	Voltage	Voltage Drop
	HPF24S6	Panel			20.4V	
1	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 15CD	9'-0	143.0000mA	20.3381V	(0.0619V)
2	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	20'-0	120.0000mA	20.2149V	(0.1232V)
3	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 95CD	31'-0	243.0000mA	20.0426V	(0.1724V)
4	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 95CD	44'-0	243.0000mA	19.8514V	(0.1912V)
5	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	33'-0	120.0000mA	19.7481V	(0.1033V)
6	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 15CD	12'-0	143.0000mA	19.7177V	(0.0304V)
7	GCS24CR	STROBE, M-C, RED, CEILING, 15CD	12'-0	120.0000mA	19.696V	(0.0218V)
8	GCC24-CR	HORN/STROBE, 2 WIRE, M-C, RED, CEILING, 95CD	42'-0	243.0000mA	19.6449V	(0.051V)
8	EOL	END OF LINE RESISTOR	3'-0	0.0000mA	19.6449V	(0V)
			206'-0	1375.0000mA		
				Т	otal Currer	nt: 1375.0000mA
		(Tot	al VDrop Per	rcent:3.70%) To	otal Voltage	e Drop : 0.7551V




WIRE DIAGRAM

Must Remain On Site


GENERAL NOTES / SCOPE OF WORK

- 1. FACTORY RECOMMENDED MINIMUM WIRING SIZES, TYPE AND CONSTRUCTION AS NOTED ON THE DRAWINGS MUST BE STRICTLY FOLLOWED. ANYONE WISHING TO MAKE CHANGES WILL DO SO AT THERE OWN RISK!!
- 2. THE CIRCUIT ROUTING AND WIRING COUNTS ON THE FLOOR PLAN DRAWINGS ARE SHOWN DIAGRAMMATIC BASED ON CONTINUOUS AND SHORTEST POSSIBLE ROUTING FROM THE CONTROL PANEL AND BETWEEN CONNECTED FIELD DEVICES WITH NO PHYSICAL OBSTRUCTIONS. THE WIRING OR CIRCUIT COUNTS (IF SHOWN) ARE PROVIDED AS A CONVENIENCE ONLY AND AS MEANS TO HASTEN INSTALLATION OR TO DETERMINE WIRING ROUTS.
- 3. WIRE SHOWN IN THIS DRAWING SET IS PERMITTED IN RACEWAYS LEADING TO FIRE PROTECTION EQUIPMENT. OTHER WIRE SHALL NOT BE PERMITTED.
- 4. FIRE ALARM SYSTEM INSTALLATION SHALL CONFORM WITH THE LATEST U.L., N.E.C., N.F.P.A., W.A.C., AND OTHER STANDARDS AS APPLICABLE TO THE CITY STANDARDS.
- 5. WHEN NECESSARY, DUE TO CHANGING DESIGN REQUIREMENTS, FACTORY AVAILABILITY, ETC. FIRE SYSTEMS WEST RESERVES THE RIGHT TO SUBSTITUTE EQUIPMENT HEREIN MENTIONED OR SPECIFIED, WITH EQUIPMENT OF EQUAL OR BETTER QUALITY, FUNCTION AND DESIGN.
- 6. PARALLEL BRANCHING OF WIRE TO ALL NOTIFICATION APPLIANCE CIRCUITS SHALL NOT BE PERMITTED.
- 7. PARALLEL BRANCHING OF WIRE TO ANALOG INITIATING DEVICE CIRCUITS IS PERMISSIBLE.
- 8. THIS SPACE IS EQUIPPED WITH AN AUTOMATIC FIRE SPRINKLER SYSTEM.
- 9. FIRE SYSTEMS WEST WILL BE INSTALLING NEW FIRE ALARM NOTIFICATION DEVICES FOR TENANT IMPROVEMENT.

	FIRE ALARM SYST					
	INSTALLER	VSUPPLIER				
SITE CONTACT:		DESIGN/SUPPLIER	:			
ABLEAU		FIRE SYSTEMS WEST, INC.				
01 PARK PLACE CE	ENTER	206 FRONTAGE ROAD NORTH, STE				
IRKLAND, WA 9803	33	PACIFIC, WASHINGTON 98047				
HONE:		PHONE: (253) 83	3-1248			
X:		FAX: (253) 735-0113				
A ST LICENSE: FI	RESWI140B1	WA ST LICENSE: FIRESWI055LW				
	DESIG	GNER				
	MATT C	ARLMAN				
	FIRE SYSTEM	IS WEST, INC				
	206 FRONTAGE RO	OAD NORTH, STE C				
	PACIFIC, WASH	HINGTON 98047				
	PHONE: (25	53) 833-1248				
	FAX: (253)	735-0113				
	x	4				





FOR FIRE DEPARTMENT USE ONLY













GENERAL NOTES / SCOPE OF WORK

- 1. FACTORY RECOMMENDED MINIMUM WIRING SIZES, TYPE AND CONSTRUCTION AS NOTED ON THE DRAWINGS MUST BE STRICTLY FOLLOWED. ANYONE WISHING TO MAKE CHANGES WILL DO SO AT THERE OWN RISK!!
- 2. THE CIRCUIT ROUTING AND WIRING COUNTS ON THE FLOOR PLAN DRAWINGS ARE SHOWN DIAGRAMMATIC BASED ON CONTINUOUS AND SHORTEST POSSIBLE ROUTING FROM THE CONTROL PANEL AND BETWEEN CONNECTED FIELD DEVICES WITH NO PHYSICAL OBSTRUCTIONS. THE WIRING OR CIRCUIT COUNTS (IF SHOWN) ARE PROVIDED AS A CONVENIENCE ONLY AND AS MEANS TO HASTEN INSTALLATION OR TO DETERMINE WIRING ROUTS.
- 3. WIRE SHOWN IN THIS DRAWING SET IS PERMITTED IN RACEWAYS LEADING TO FIRE PROTECTION EQUIPMENT. OTHER WIRE SHALL NOT BE PERMITTED.
- 4. FIRE ALARM SYSTEM INSTALLATION SHALL CONFORM WITH THE LATEST U.L., N.E.C., N.F.P.A., W.A.C., AND OTHER STANDARDS AS APPLICABLE TO THE CITY STANDARDS.
- 5. WHEN NECESSARY, DUE TO CHANGING DESIGN REQUIREMENTS, FACTORY AVAILABILITY, ETC. FIRE SYSTEMS WEST RESERVES THE RIGHT TO SUBSTITUTE EQUIPMENT HEREIN MENTIONED OR SPECIFIED, WITH EQUIPMENT OF EQUAL OR BETTER QUALITY, FUNCTION AND DESIGN.
- 6. PARALLEL BRANCHING OF WIRE TO ALL NOTIFICATION APPLIANCE CIRCUITS SHALL NOT BE PERMITTED.
- 7. PARALLEL BRANCHING OF WIRE TO ANALOG INITIATING DEVICE CIRCUITS IS PERMISSIBLE.
- 8. THIS SPACE IS EQUIPPED WITH AN AUTOMATIC FIRE SPRINKLER SYSTEM.
- 9. FIRE SYSTEMS WEST WILL BE INSTALLING NEW FIRE ALARM NOTIFICATION DEVICES FOR TENANT IMPROVEMENT.

		EM INFORMATION SUPPLIER			
SITE CONTACT:	MOTALLLI	DESIGN/SUPPLIER	•		
TABLEAU		FIRE SYSTEMS WEST, INC.			
401 PARK PLACE CI	ENTER	206 FRONTAGE ROAD NORTH, STE			
KIRKLAND, WA 9803		PACIFIC, WASHINGTON 98047			
PHONE:		PHONE: (253) 83	3-1248		
FAX:		FAX: (253) 735-0	113		
WA ST LICENSE: FI	RESWI140B1	WA ST LICENSE:	FIRESWI055LW		
	DESI	GNER			
	MATT C	ARLMAN			
	FIRE SYSTEM	AS WEST, INC			
		DAD NORTH, STE C			
		HINGTON 98047			
		53) 833-1248			
	FAX: (253	735-0113			
	x	4			
	FOR FIRE DEPAR	TMENT USE ONLY			









 DATE:
 01/22/2016
 TABLEAU
 TITAN ELECT

 SCALE:
 1/8" = 1'-0"
 KIRKLAND, WA 98033
 BELLEVUE, WA

 SHEET:
 FA-02
 ON-SITE CONTACT: DAVID CROOK 425-250-3588